File No.GVMC-FNOC0EDN(RNL)/76/2018-SFO(TP)-GVMC



GREATER VISAKHAPATNAM MUNICIPAL CORPORATION FIRE PREVENTION WING

From:

To:

The Commissioner, Greater Visakhapatnam

The District Educational Officer,

Municipal Corporation,

Visakhapatnam District.

Visakhapatnam.

Visakhapatnam

Rc.No.358/RFO/FPW/GVMC/2023, Dt.25-10-2023

SUB: Greater Visakhapatnam Municipal Corporation - Fire Prevention Wing- Existing Building of M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam - Revised Renewal of Fire No Objection Certificate - Issued - Regarding.

REF: 1. Letter Rc.No:5041/B2/97 of Director General, A.P.Disaster Response & Fire Services Department, Dated: 12-03-2010.

Delegation orders of the Commissioner, GVMC vide Rc.No.6721/2012/TP. Sec/G1 Dt:13/09/2019.

3. This Office Fire No Objection Certificate for Occupancy Rc.No.6059/14/FPW/GVMC, Dt.01-05-2014.

4. This Office Renewal of Fire No Objection Certificate issued vide Rc.No.00226/20/FPW/GVMC, Dt.27-10-2020.

Application Dated: 18-10-2023 of M/s. Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam for Revised Renewal of Fire NOC.

*** *** ***

It is to inform that vide reference 4th cited, Renewal of Fire No Objection Certificate was issued to M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam.

- Vide reference 5th cited, an application is received by this office for issuance of Revised Renewal of Fire No Objection Certificate duly changing Plot area in the NOC.
- Therefore, the District Fire Officer and Station Fire Officer of Fire Prevention Wing visited the premises of M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam on 19-10-2023 and submitted the following report.

4) Particulars of The building:

| a) | Address of the Premises | M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam |
|----|-------------------------|--|
| b) | Total Plot Area | 6,177.00 Sq. Mtrs (Block-I & II) |
| c) | Height of the Building | 13.00Mtrs |
| d) | No of blocks/ floors | 02 Blocks / Stilt + Ground + 02 Upper Floors |
| e) | Type of occupancy | Educational Building (School) |

BLOCK-I

5) The floor wise details.

PREVENTIV

| Sl.No. | Floor | Area in Sq. Meters. | Type of Occupancy |
|--------|--------|---------------------|----------------------|
| 1. | Ground | 443.10 | Educational (School) |
| 2. | First | 508.38 | Educational (School) |
| 3. | Second | 483.82 | Educational (School) |
| 4. | Third | 483.82 | Educational (School) |
| 77 | Total | 1919.12 | |

6)The Builder has provided the following open places all round building.

| Direction | Open space provided 2.70 | |
|---------------|-----------------------------|--|
| North (Front) | | |
| South | 7.50 | |
| East | 4.00 | |
| West | 2.70 | |

4 Hested Copy

Contd.p.2

Corriespondent PLE I EM SCHOOL

Srinagar, Galayaka (P.O.) khapatnam-530 026 (A.P.)

et Muly APPLE I EM SCHOOL Srinagar, Gajuwaka (P.O.) Visakhapatnam-530 026 (A.P.)

Gajuwaka

File No.GVMC-FNOC0EDN(RNL)/76/2018-SFO(TP)-GVMC

:: 2 ::

7) Means Escape:

 The Management has provided One Internal Staircase with width of 1.20 Mtrs. from Ground floor to Terrace.

8) The Minimum Fire Safety Installations required & provided by the Builder as per the

Table-23 and other relevant clauses of part-4of N.B.C of India 2005.

| Sl.No. | Fire Safety Measures | Required | Provided | Deficit |
|--------|-----------------------------------|--------------|--------------|---------|
| 1 | Fire Extinguishers as per IS 2190 | 19 No's | 19 No's | Nil |
| 2 | Hose Reel | 04 Nos. | 04 Nos. | Nil |
| 3 | Down comer | 01 No. | 01 No. | |
| 4 | Terrace Tank | 10,000 Ltrs. | 10,000 Ltrs. | Nil |
| 5 | Booster Pump | 450 LPM | 450 LPM | Nil |

BLOCK-II

9) The floor wise details.

| Sl. No. | Floor | Area in Sq. Meters. | Type of Occupancy |
|------------|--------|---------------------|----------------------|
| 1. | Ground | 277.96 | Educational (School) |
| 2. | First | 277.96 | Educational (School) |
| 3. | Second | 277.96 | Educational (School) |
| 4., | Third | 277.96 | Educational (School) |
| | Total | 1111.84 | |

10) The Builder has provided the following open places all round building.

| Direction | Open space provided | |
|---------------|---------------------|--|
| North (Front) | 2.70 | |
| South | 7.00 | |
| East | 2.00 | |
| West | 4.00 | |

11) Means Escape:

 The Management has provided One Internal Staircase & One External Staircase with width of 1.00 Mtr. each from Ground floor to Terrace.

12) The Minimum Fire Safety Installations required & provided by the Builder as per the

Table -23 and other relevant clauses of part-4 of N.B.C of India 2005.

| Sl. No. | Fire Safety Measures | Required | Provided | Deficit |
|---------|-----------------------------------|--------------|--------------|---------|
| 1 | Fire Extinguishers as per IS 2190 | 12 No's | 12 No's | Nil |
| 2 | Hose Reel | 04 Nos. | 04 Nos. | Nil |
| 3 | Down comer | 01 No. | 01 No. | Nil |
| 4 | Terrace Tank | 10,000 Ltrs. | 10,000 Ltrs. | Nil |
| 5 | Booster Pump | 450 LPM | 450 LPM | Nil |

- 13) The management has remitted an amount of Rs.3,031/- vide challan No.2023-CA-053607, Dt.18-10-2023 towards fire precautionary fees for Revision of Plot area in NOC.
- 14) The District Fire Officer & Station Fire Officer, Fire Prevention Wing, GVMC visited the site and recommended for issuance of Revised Renewal of Fire No Objection Certificate.
- 15) Therefore, **Revised Renewal of Fire No Objection Certificate** is hereby issued to M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam subject to the following conditions:

| | 3 |
|--|--|
| i. | All the protection arrangements shall be maintained in good condition as seen during inspection |
| ii. | All the escape / exit routes shall not be kept locked / blocked or encroached |
| iii. | All the occupants must know the correct method of operation of the fire fighting system installed |
| iv. | Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management. |
| v. | All students / staff members of the institution shall be trained to operate the fire safety equipments during Emergency. |
| vi. | Addition / alteration, if any in the building may be obtained with prior |
| STORES OF THE PERSON NAMED IN COLUMN 1 | permission from this department |

Correspondent

APPLE ! EM SCHOOL

Srinagar, Gajuwaka (P.O.)

Visakhapatnam-530 026 (A.P.)

Principal
APPLE I EM SCHOOL

Srinagar, Gajuwaka (P.O.) Visakhapatnam-530 026 (A.P.)

Gajuwaka VSP-26

PEVENTO TO STANDARD OF THE PERSON OF THE PER

File No.GVMC-FNOC0EDN(RNL)/76/2018-SFO(TP)-GVMC

:: 3 ::

- vii. Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
- 16) The Revised Renewal of Fire No Objection Certificate
 School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka,
 Visakhapatnam is valid from 18-11-2020 to 17-11-2025 and the Management shall
 submit the application for Renewal of Fire No Objection Certificate two (2) months
 before the date of expiry.

17) The issuing of Fire NOC is without any prejudice to take action by GVMC against Unauthorized Construction, if any made.

Regional Fire Officer
Fire Prevention Wing,
Greater Visakhapatnam Municipal Corporation,
Visakhapatnam

Copy to:

The Chief City Planner, GVMC, Visakhapatnam.

2) The Management, M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam

Attested CSP

Correspondent

APPLE I EIVI SCHOOL

Srinagar, Gujuraka (P.O.)

Srinagar, Gujudvaka (P.O.) Visakhapatnam-530 026 (A.P.) Gajuwaka VSP-26

Principal
APPLE I EM SCHOOL
Srinagar; Gajuwaka (P.O.)
Visakhapatnam-530 026 (A.P.)

Lauret Merkhy